



Certificate of Compliance

Certificate: 1443677

Master Contract: 220734

Project: 70034688

Date Issued: August 18, 2015

Issued to: Newson Gale Limited
Omega House
Private Road 8
Colwick, Nottingham,
NG4 2JX, UK

Attention: Mr. Ian Edge

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Goutam Das
Goutam Das

PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations

CLASS 2258 84 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations -
CERTIFIED TO U.S. STANDARDS

Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III, Division 1:

Model "Bond-Rite Clamp II" Bonding Clamp; intrinsically safe, hand-held-portable, battery operated (one 9V Ultralife U9VL-J 9V or Varta type 6122 Lithium Manganese cell); Tambient: -40 C to +60 C; Temperature Code T4.

Model "OhmGuard" I.S. Continuity Tester; intrinsically safe, hand-held-portable, battery operated (one 9V Ultralife U9VL-J 9V or Varta type 6122 Lithium Manganese cell); Tambient: -40 C to +60 C; Temperature Code T4.

Note: This certification does not cover the performance of the equipment in regards to its efficiency to ground the metallic plant.



Certificate: 1443677
Project: 70034688

Master Contract: 220734
Date Issued: August 18, 2015

APPLICABLE REQUIREMENTS

- | | |
|------------------------------|---|
| C22.2 No. 0-10 | - General Requirements – Canadian Electrical Code, Part II |
| CAN/CSA-C22.2 No. 157-92 | - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations |
| UL 913 (5 th Ed.) | - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II and III, Division 1, Hazardous Locations |