



Online  
Inquiry >

Technical Article

## Hydrogen Safety: the importance of controlling static electricity

*Countries around the world have set the strategic objective of reaching net-zero as soon as possible. One of the key enablers is the rapid development of the hydrogen economy. Vast amounts of public and private money are being invested in the production, storage and transportation of hydrogen as well as the fueling station network for the increasing range of hydrogen vehicles.*

As the hydrogen economy rapidly develops, safety must be the top priority. Standardization is a key step on this journey to net-zero. The ISO 19880-1:2020 Standard is very specific about the requirements for grounding and bonding, including for hydrogen delivery systems such as trucks or trailers. The Standard states that electrical resistance between metallic parts connected or in contact together should be less than 10 ohms.

## Static Electricity as an Ignition Source

Each day there are fires and explosions caused by the ignition of flammable and combustible chemicals. One of the most common causes of the ignition is a spark caused by a sudden discharge of accumulated static electricity.

When two differing materials move against each other, electrons can be exchanged, leaving an excess of positive charge on one material and an equal negative charge on the other. This is the generation of static electricity. During the transfer or processing of a material, significant amounts of static charge can accumulate very quickly, leading to the rapid increase of voltage on the object (e.g. road tanker).

Voltages can rapidly exceed the break-down voltage of the surrounding atmosphere and create the risk of a sudden discharge to a nearby conductor in the form of a spark.

The amount of energy released by this sudden discharge can easily exceed the Minimum Ignition Energy (MIE) of the potentially flammable atmosphere and thereby lead to a fire or explosion.



### Newson Gale exists to design and manufacture solutions to mitigate against this risk.

The most effective way of avoiding a sudden static discharge is to ensure the object is grounded before and during the process by providing a low resistance path to true ground so that static electricity does not accumulate.

Incident Type	Incident Number	Facility	Date	Location	Casualties
Explosion	1	Large Storage Tank	1953	Germany	29 Fatalities
Explosion	2	Large Storage Tank	1954	The Netherlands	-
Explosion	1	Loading Tanker	1956	USA	-
Explosion	1	Tanker	1966	USA	-
Explosion	3	Crude Oil Tanker	1969	The Netherlands	
Fire & Explosion	303	Filling of Containers (storage tanks, road, rail tanks and drums)	1979-1988	UK	5 Fatalities & 100 Injuries
Fire	243	Petrol Stations	1993-2004	Around the World	-

Table 1, Summary of static ignition incidents  
 (Source: "An overview on static electricity", Disaster Prevention and Management: An International Journal, (2008))

ISO/TR 15916:2015(E)

B.3 Comparison of hydrogen with other common fuels.  
 Table B.2 compares the ignition and combustion properties of hydrogen and other common fuels.  
 Table B.2 Ignition and combustion properties for air mixtures at 25°C and 101,3 kPa for several common fuels.

Fuel	Lower flammability limit % vol. fraction	Stoichiometric mixture % vol. fraction	Upper flammability limit % vol. fraction	Minimum ignition energy mJ	Auto-ignition temperature K	Laminar burning velocity m/s
Hydrogen	4	29.5	77	0.017	858	2.70
Methanol	6.0	12.3	36.5	0.174	658	0.48
Methane	5.3	9.5	17.0	0.274	810	0.37
Propane	1.7	4.0	10.9	0.240	723	0.47
Gasoline	1.0	1.9	6.0	0.240	488	0.30

### The Specific Properties of Hydrogen

The reason that controlling static electricity is so important for hydrogen safety is that the MIE is only a fraction of that of other fuels. This is highlighted in the following table taken from the *ISO Technical Report ISO / TR 15916 'Basic considerations for the safety of hydrogen systems'*.

The very small amount of energy required to ignite hydrogen means that it is classified within Gas Group IIC (Gas Group B in the US). Newson Gale's **Earth-Rite® II RTR** is dedicated to grounding tank trucks and large vehicles. It is certified to be installed and used in IIC environments, unlike many alternative systems.

The ease with which hydrogen can be ignited was outlined by S Tretsiakova-McNally, Ulster University, in *'Lecture: sources of hydrogen ignition and prevention measures'* (Page 10):

*"Thus, whilst electrostatic charging of those who refuel their vehicles with petrol rarely gives rise to ignitions, it is significant that the voltage required for hydrogen to be ignited is below 2kV. This voltage can be generated easily on people, without them being aware of it, standing on an insulating surface, so there is a potential for personnel to ignite hydrogen leaks very easily, without any apparent ignition source being present."*

The most famous incident involving the ignition of hydrogen is the 1937 Hindenburg airship disaster. This massive airship was filled with hydrogen and became engulfed in flames, causing 36 fatalities. According to Konstantinos Giapis, Professor of Chemical Engineering at Caltech, the ignition was caused by sparks as static electricity discharged.



In the article, *'Statistical analysis of fires and explosions attributed to static electricity over the last 50 years in Japanese industry'*, Ohsawa found that 9% of such incidents involved hydrogen.

The ISO Technical Report on hydrogen safety clearly recognizes a high-energy spark discharge as a major risk (5.3.7) and refers the reader to the recommended practices for grounding methods that can be found in various national and international standards (7.3.3.1).

## Legislation concerning static electricity in hazardous atmospheres

The ignition risk posed by static electricity is addressed in European and North American legislation.

In Europe, Annex II of the *ATEX Directive 2014/34/EU* within Section 1.3.2 states: *“Hazards arising from static electricity: Electrostatic charges capable of resulting in dangerous discharges must be prevented by means of appropriate measures”*.

In the US, the Code of Federal Regulations that addresses hazardous location activities, *29 CFR Part 1910 Occupational Safety and Health Standards*, states that *“All ignition sources potentially present in flammable atmospheres, including static electricity, shall be mitigated or controlled”*.

Section 10.12 of Canada’s *Occupational Health and Safety Regulations (SOR/86-304)* states that if a substance is flammable and static electricity is a potential ignition source that the employer *“shall implement the standards set out in the United States National Fire Protection Association, Inc. publication NFPA 77, Recommended Practice on Static Electricity.”*

## Industry Codes of Practice

*NFPA 77, Recommended Practice on Static Electricity* is one of a number of industry codes of practice that addresses the ignition hazards of static electricity. In recognition of the ignition risks posed by static electricity these publications are produced and edited by committees of technical experts that participate in the hazardous process industries.

**The publications in the table below are dedicated to helping QHSE professionals and plant engineers identify and control electrostatic ignition sources.**

Publisher	Title	Metal Grounding Circuits
International Electrotechnical Commission	IEC TS 60079-32-1: Explosive Atmospheres, Electrostatic Hazards Guidance	10 Ω
National Fire Protection Association	NFPA 77: Recommended Practice on Static Electricity	10 Ω
American Petroleum Institute	API RP 2003: Protection against Ignitions Arising out of Static, Lightning and Stray Currents	10 Ω*
American Petroleum Institute	API 2219: Safe Operation of Vacuum Trucks in Petroleum Service	10 Ω

*List of industry codes of practice designed to prevent ignitions caused by static electricity.*


*\*API RP 2003 States that 10 Ω is ‘satisfactory’*

NOTE: Always check for and read the latest version of the International Standards and/or Recommended Practices.

## Target $\leq 10$ ohms

Due to the harsh industrial environments in which grounding equipment typically operates, and because most grounding applications require many repeated connections and disconnections to process equipment, the robustness and reliability of the grounding solution is the primary concern with respect to intended performance. For that reason, best practice guidance such as *IEC TS 60079-32-1* and *NFPA 77* recommend resistance levels of 10 ohms or less between the object requiring static grounding and the verified grounding point. The reason for this is that resistances higher than 10 ohms in the circuit between the object and the verified grounding point could indicate potential compromise of the grounding circuit, like a poor initial connection to the equipment via the grounding clamp, or loose / corroding connections that could otherwise prevent the passage of static charges to ground.

The most practical way to verify a resistance level of 10 ohms or less between the object to be grounded and the verified grounding point during the process is to use a monitored grounding system. A grounding system that continually monitors to a 10 ohm or less permissive threshold provides continuous indication of a connection that adheres to international standards and best practice recommendations.



Newson Gale's **Earth-Rite® II** range of monitored grounding systems have achieved third-party verification (SIRA / CSA) of the 10 ohms or less permissive resistance threshold helping achieve compliance with international standards and best practice recommendations. Newson Gale is not aware of any other supplier having obtained a similar certificate confirming the 10 ohms or less performance.

## International Standard

### *ISO 19880-1:2020 Gaseous hydrogen – Fuelling Stations*

This Standard, dated March 2020, defines the minimum design requirements for the safety of all hydrogen fuelling stations. It covers fuelling stations for the following vehicles:

- Motorcycle
- Fork-lift truck
- Car
- Bus
- Truck
- Tram
- Train

The scope of the Standard also includes hydrogen delivery systems such as trucks or trailers. Mobile fuelling stations are also covered.

The Standard includes a section addressing the need to mitigate the risk from static electricity.

### 10.2.3 Protection from ignition due to the accumulation of static charge

This section of the ISO 19880-1:2020 Standard is very specific about the requirements for grounding and bonding. Fortunately, Newson Gale's products meet all of the requirements.

*"Hydrogen systems shall be equipotentially bonded and grounded to prevent build-up of electrostatic charge ... Electrical continuity should be ensured throughout the hydrogen system ... The electrical resistance between metallic parts connected or in contact together should be less than 10 ohms."*

As discussed before, the Newson Gale **Earth-Rite® II** range of grounding systems continually monitor the connection resistance to a 10 ohms or less permissive threshold, and this has been verified by a third-party testing house.

*"All hydrogen delivery vehicles shall be equipotentially bonded to the fixed storage hardware prior to flexible hose connection."*

The Newson Gale **Earth-Rite® II RTR** verifies that it has been connected to an object with a capacitance typical of a large vehicle. This can mitigate against the risk of non-compliance with the Standard Operating Procedure.

This function of the **Earth-Rite® II RTR** also makes it the ideal product for the grounding of a large vehicle such as a truck or bus while it is being refueled.



*"The bonded hydrogen systems shall be grounded. The grounding system resistance shall be less than 1 megohm from any part within the hydrogen system."*

The Newson Gale **Earth-Rite® II RTR** and **MGV** grounding systems verify that the true ground resistance is less than approximately 1000 ohms.

*"Grounding devices should be clearly visible or be essential to the correct functioning of the fuelling station, so that any shortcomings are quickly detected."*

If all of the parameter checks confirm permitted levels, the Newson Gale **Earth-Rite® II** grounding system will give clear visual indication of the 'GO' condition from three high-intensity flashing green LEDs. If any of the checks fails to confirm a permitted level, a solid red LED indicates the 'NO-GO' condition.



The **Earth-Rite® II RTR** also has the capability to be interlocked with the process so the flow of hydrogen in conjunction with the process control system can be controlled as per the 'GO / NO-GO' condition.

*"Grounding devices should be robust and so installed that they are not affected by high resistance contamination, for example, by corrosion products or paint."*

Newson Gale pioneered the use of solid tungsten carbide teeth in grounding clamps. These very hard and very sharp teeth ensure a metal-to-metal contact with a bite that is capable of penetrating through corrosion or paint.

## Why choose Newson Gale as your static grounding partner?

As already outlined, Newson Gale's range of static grounding systems help achieve compliance with the requirements of the new hydrogen ISO 19880-1:2020 Standard. There are also other reasons why companies that handle hazardous materials choose Newson Gale:

- Newson Gale has built a reputation for designing and manufacturing the most reliable static grounding systems on the market today.
- Over the last 40 years, Newson Gale has supplied tens of thousands of systems globally to protect people and plant from the ignition hazards of static electricity.
- Newson Gale systems have achieved global certification, so you can standardize your specification at various locations (see below).

- A global distribution network means that all your locations can access Newson Gale's market-leading products.
- Our CompEx trained technical department and sales engineers are available online or on-site anywhere to demonstrate products and to tailor solutions to each application.
- With the broadest range of products in the market, Newson Gale has a solution for many applications and budgets.

Contact us today for more information:  
[www.newson-gale.com](http://www.newson-gale.com)



IECEX



SIL 2



### References:

International Standards Organisation ISO 19880-1:2020 Gaseous hydrogen – fueling stations, <https://www.iecex.com/publications/standards/>

International Electrotechnical Commission IEC TS 60079-32-1:2013+AMD1:2017 CSV, 'Amendment 1 - Explosive atmospheres - Part 32-1: Electrostatic hazards, guidance', <https://webstore.iec.ch/publication/26519>

National Fire Protection Association NFPA 77, Recommended Practice on Static Electricity, 2019 Edition, <https://www.nfpa.org/codes-and-standards/all-codes-and-standards/list-of-codes-and-standards/detail?code=77>

S Treisiakova-McNally, Ulster University, Lecture: sources of hydrogen ignition and prevention measures, [http://www.hyresponse.eu/files/Lectures/Sources\\_of\\_hydrogen\\_ignition\\_notes.pdf](http://www.hyresponse.eu/files/Lectures/Sources_of_hydrogen_ignition_notes.pdf)

Professor Konstantinos Giapis of Caltech on the Hindenburg airship disaster, <https://www.caltech.edu/about/news/history-mysteries-caltech-professor-helps-solve-hindenburg-disaster>

Ohsawa: Statistical analysis of fires and explosions attributed to static electricity over the last 50 years in Japanese industry, <https://iopscience.iop.org/article/10.1088/1742-6596/301/1/012033/pdf>

**Note** – Please ensure you are always accessing the latest version of any applicable standard or guidance document.

#### Copyright Notice

The website and its content is copyright of Newson Gale Ltd © 2020. All rights reserved.

Any redistribution or reproduction of part or all of the contents in any form is prohibited other than the following:

- you may print or download to a local hard disk extracts for your personal and noncommercial use only
- you may copy the content to individual third parties for their personal use, but only if you acknowledge the website as the source of the material

You may not, except with our express written permission, distribute or commercially exploit the content. Nor may you transmit it or store it in any other website or other form of electronic retrieval system.

#### Right to change

This document provides general information only and may be subject to change at any time without notice. All information, representations, links or other messages may be changed by Newson Gale at any time without prior notice or explanation.

Newson Gale is not obliged to remove any outdated information from its content or to expressly mark it as being outdated. Please seek the advice of professionals as necessary regarding the evaluation of any content.

#### Disclaimer of liability

The information provided in this Technical Article is provided by Newson Gale without any representations or warranties, expressed or implied, as to its accuracy or completeness. The liability of Newson Gale for any expenses, losses or actions incurred whatsoever by the recipient as a result of the use of this Technical Article shall be excluded.

Leading the way in hazardous area static control



7/7

#### United Kingdom

**Newson Gale Ltd**  
Omega House  
Private Road 8  
Colwick, Nottingham  
NG4 2JX, UK  
+44 (0)115 940 7500  
groundit@newson-gale.co.uk

#### United States

**IEP Technologies LLC**  
417-1 South Street  
Marlborough, MA 01752  
USA  
+1 732 961 7610  
groundit@newson-gale.com

#### Deutschland

**IEP Technologies GmbH**  
Kaiserswerther Str. 85C  
40878 Ratingen  
Germany  
+49 (0)2102 5889 0  
erdung@newson-gale.de